

ADDENDUM TO FACT SHEET
Permit No. WA-002374-4
Post Point Wastewater Treatment Plant
December 18, 2007

This is an addendum to the fact sheet accompanying permit number WA-002374-4, issued to the City of Bellingham for its Post Point Wastewater Treatment Plant on November 2, 2007. The following minor and/or typographical errors were brought to Ecology's attention by the Permittee. The following minor modifications have been made to the permit in response.

- Cover page: The latitude and longitude for the alternate outfall were not available until after the permit was issued. They are now included.
- Page 5: The Total Suspended Solids average monthly value for removal of influent TSS should be 80%, not 85%.
- Page 20: The value for the following test: "Mysid shrimp, *Mysidopsis bahia*/*Americamysis bahia* (48-hour static test, method: EPA-821-R-02-014)," should be EPA-821-R-02-012.
- Page 24: Condition S.12. The second sentence should read, "Bypasses that occur that are under this amount or are not wet weather related are not authorized under this condition and are subject to the bypass provisions as stated in condition S5.F of the permit." The permit currently cites the condition as S5.E.

The changes to this permit constitute minor modifications under 40 CFR 122.63.