

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
WASTE DISCHARGE PERMIT No. WA-002264-1

State of Washington  
DEPARTMENT OF ECOLOGY  
Bellingham Field Office  
1204 Railroad Avenue Suite 200  
Bellingham, WA 98225-5089

In compliance with the provisions of  
The State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington  
and  
The Federal Water Pollution Control Act  
(The Clean Water Act)  
Title 33 United States Code, Section 1251 et seq.

**City of BLAINE**

1200 Yew Avenue  
Blaine, WA 98230

Plant Location:  
9235 Semiahmoo Parkway  
Blaine, WA 98230

Receiving Water:  
Strait of Georgia

Waterbody I.D. No.:  
12229892484144

Discharge Location:  
Latitude: 48° 58' 46" N  
Longitude: 122° 48' 05" W

Plant Type:  
Rotating Biological Contactors

is authorized to discharge in accordance with the Special and General Conditions that follow.

---

Richard M. Grout  
Manager  
Bellingham Field Office  
Washington State Department of Ecology

## TABLE OF CONTENTS

SUMMARY OF PERMIT REPORT SUBMITTALS.....	4
<b>SPECIAL CONDITIONS</b>	
S1. DISCHARGE LIMITATIONS.....	5
A. Effluent Limitations	
B. Mixing Zone Descriptions	
S2. MONITORING REQUIREMENTS.....	6
A. Monitoring Schedule	
B. Sampling and Analytical Procedures	
C. Flow Measurement	
D. Laboratory Accreditation	
S3. REPORTING AND RECORDING REQUIREMENTS.....	9
A. Reporting	
B. Records Retention	
C. Recording of Results	
D. Additional Monitoring by the Permittee	
E. Twenty-four Hour Notice of Noncompliance Reporting	
F. Immediate Noncompliance Notification	
G. Other Noncompliance Reporting	
H. Maintaining a Copy of This Permit	
S4. FACILITY LOADING.....	12
A. Design Criteria	
B. Plans for Maintaining Adequate Capacity	
C. Duty to Mitigate	
D. Notification of New or Altered Sources	
E. Infiltration and Inflow Evaluation	
F. Waste Load Assessment	
S5. OPERATION AND MAINTENANCE.....	15
A. Certified Operator	
B. O & M Program	
C. Short-term Reduction	
D. Electrical Power Failure	
E. Prevent Connection of Inflow	
F. Bypass Procedures	
G. Operations and Maintenance Manual	
S6. PRETREATMENT.....	18
A. General Requirements	
B. Wastewater Discharge Permit Required	
C. Identification and Reporting of Existing, New, and Proposed Industrial Users	
D. Industrial User Survey	
E. Duty to Enforce Discharge Prohibitions	

S7. RESIDUAL SOLIDS..... 21

S8. APPLICATION FOR PERMIT RENEWAL .....22

S9. ACUTE TOXICITY .....22

    A. Testing Requirements

    B. Sampling and Reporting Requirements

S10. CHRONIC TOXICITY.....23

    A. Testing Requirements

    B. Sampling and Reporting Requirements

S11. OUTFALL EVALUATION .....25

**GENERAL CONDITIONS**

G1. SIGNATORY REQUIREMENTS.....26

G2. RIGHT OF INSPECTION AND ENTRY .....27

G3. PERMIT ACTIONS.....27

G4. REPORTING PLANNED CHANGES.....28

G5. PLAN REVIEW REQUIRED .....29

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES.....29

G7. TRANSFER OF THIS PERMIT .....29

G8. REDUCED PRODUCTION FOR COMPLIANCE .....30

G9. REMOVED SUBSTANCES .....30

G10. DUTY TO PROVIDE INFORMATION.....30

G11. OTHER REQUIREMENTS OF 40 CFR.....30

G12. ADDITIONAL MONITORING.....30

G13. PAYMENT OF FEES.....30

G14. PENALTIES FOR VIOLATING PERMIT CONDITIONS .....30

G15. UPSET .....31

G16. PROPERTY RIGHTS.....31

G17. DUTY TO COMPLY .....31

G18. TOXIC POLLUTANTS.....31

G19. PENALTIES FOR TAMPERING .....32

G20. REPORTING ANTICIPATED NONCOMPLIANCE.....32

G21. REPORTING OTHER INFORMATION.....32

G22. COMPLIANCE SCHEDULES .....32

**SUMMARY OF PERMIT REPORT SUBMITTALS**

Refer to the Special and General Conditions of this permit for additional submittal requirements.

<b>Permit Section</b>	<b>Submittal</b>	<b>Frequency</b>	<b>First Submittal Date</b>
S3.	Discharge Monitoring Report	Monthly	December 15, 2008
S3.E.	Noncompliance Notification	As necessary	
S3.	Shellfish Protection	As necessary	
S4.B.	Plans for Maintaining Adequate Capacity	As necessary	
S4.C.	Notification of New or Altered Sources	As necessary	
S4.E.	Infiltration and Inflow Evaluation	Annually	January 31, 2008, and annually thereafter
S4.F.	Waste load Assessment	Annually	January 31, 2008, and annually thereafter
S5.G.	Operations and Maintenance Manual Update or Review Confirmation Letter	Annually	January 31, 2008
S6.D.	Industrial User Survey	1/permit cycle	January 31, 2011
S8.	Application for Permit Renewal	1/permit cycle	May 15, 2012
S9.E.	Acute Toxicity Effluent Test Results with Permit Renewal Application	2/permit cycle	June 30, 2011 and December 28, 2011 (Once in the last summer & once in the last winter prior to submission of the renewal application)
S10.E.	Chronic Toxicity Effluent Test Results with Permit Renewal Application	2/permit cycle	June 30, 2011 and December 28, 2011 (Once in the last summer & once in the last winter prior to submission of the renewal application)
S11.	Outfall Evaluation	1/permit cycle	January 31, 2012
G1.	Notice of Change in Authorization	As necessary	
G4.	Reporting Planned Changes	As necessary	
G5.	Engineering Report for Construction or Modification Activities	As necessary	
G21.	Reporting Anticipated Noncompliance	As necessary	

## SPECIAL CONDITIONS

### S1. DISCHARGE LIMITATIONS

#### A. Effluent Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on the effective date of this permit and lasting through the expiration date, the Permittee is authorized to discharge municipal wastewater at the permitted location subject to complying with the following limitations:

<b>EFFLUENT LIMITATIONS<sup>a</sup>: OUTFALL # 1</b>		
<b>Parameter</b>	<b>Average Monthly</b>	<b>Average Weekly</b>
Biochemical Oxygen Demand (5-day)	30 mg/L, 200 lbs/day 85% removal of influent BOD	45 mg/L, 300 lbs/day
Total Suspended Solids	30 mg/L, 200 lbs/day 85% removal of influent TSS	45 mg/L, 300 lbs/day
Fecal Coliform Bacteria	200/100 mL	400/100 mL
pH <sup>b</sup>	Daily minimum is equal to or greater than 6.0 and the daily maximum is less than or equal to 9.0.	
<b>Parameter</b>	<b>Average Monthly</b>	<b>Maximum Daily<sup>c</sup></b>
Total Residual Chlorine	0.35 mg/L	0.9 mg/L
<sup>a</sup> The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform, which is based on the geometric mean.		
<sup>b</sup> Indicates the range of permitted values. The instantaneous maximum and minimum pH shall be reported monthly. The pH shall not be averaged.		
<sup>c</sup> The maximum daily effluent limitation is defined as the highest allowable daily discharge. The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement of the pollutant over the day. This does not apply to pH.		

**B. Mixing Zone Descriptions**

Acute Mixing Zone	<b>19:1</b>
Chronic Mixing Zone	<b>72:1</b>
Human Health Criteria – Carcinogen	<b>72:1</b>
Human Health Criteria – Non-carcinogen	<b>72:1</b>

*Chronic Mixing Zone*

WAC 173-201A-400(7)(b)(i) specifies mixing zones shall not extend in any horizontal direction from the discharge ports for a distance greater than 200 feet plus the depth of water over the discharge ports as measured during mean lower low water (MLLW). Since the Permittee's outfall is at a MLLW water depth of -37 feet, the horizontal chronic mixing zone distance is 237 feet. The chronic mixing zone is therefore defined as circles with diameters of 484 feet with centers at each discharge port. The distance between the ports is 14 feet, so the chronic mixing zone is an oval with dimensions of 498 feet by 484 feet. The mixing zone extends from the seabed to the top of the water surface. Chronic aquatic life criteria and human health criteria must be met at the edge of the chronic zone.

*Acute Mixing Zone*

WAC 173-201A-400(8)(b) specifies that in estuarine waters a zone where acute criteria may be exceeded shall not extend beyond 10 percent of the distance established for the maximum or chronic zone as measured from the discharge ports. The acute mixing zone for this outfall is an oval with dimensions of 62 feet by 48 feet. The mixing zone extends from the seabed to the top of the water surface. Acute aquatic life criteria must be met at the edge of the acute zone.

**S2. MONITORING REQUIREMENTS**

**A. Monitoring Schedule**

The Permittee shall monitor in accordance with the following schedule:

<b>Category</b>	<b>Parameter</b>	<b>Units</b>	<b>Sample Point</b>	<b>Minimum Sampling Frequency</b>	<b>Sample Type</b>
Wastewater Influent	BOD <sub>5</sub>	mg/L	Influent	2/week	24-hour composite
Wastewater Influent	TSS	mg/L	Influent	2/week	24-hour composite
Wastewater Influent	pH	Standard Units	Influent	Daily	Measurement
Wastewater Effluent	Flow	MGD	Final Effluent	Daily	Continuous
Wastewater Effluent	BOD <sub>5</sub>	mg/L	Final Effluent	2/week	24-hour composite

Category	Parameter	Units	Sample Point	Minimum Sampling Frequency	Sample Type
Wastewater Effluent	BOD <sub>5</sub>	lbs/day	Final Effluent	2/week	Calculate
Wastewater Effluent	BOD <sub>5</sub>	% removal	Final Effluent	2/week	Calculate
Wastewater Effluent	TSS	mg/L	Final Effluent	2/week	24-hour composite
Wastewater Effluent	TSS	lbs/day	Final Effluent	2/week	Calculate
Wastewater Effluent	TSS	% removal	Final Effluent	2/week	Calculate
Wastewater Effluent	pH	Standard Units	Final Effluent	Daily	Measurement
Wastewater Effluent	Temperature For analog recorders see footnote a	°C	Final Effluent	Daily	Measurement
Wastewater Effluent	Chlorine	mg/L	Final Effluent	Daily	Grab
Wastewater Effluent	Fecal Coliform	Org./100 mL	Final Effluent	4/Week	Grab
Sludge Pretreatment	As specified in Section S6.				
Acute Toxicity Testing	Whole Effluent Toxicity Testing		Final Effluent before Chlorination	Once in the winter and once in the summer the year prior to next permit application	24-hour composite
Chronic Toxicity Testing	Whole Effluent Toxicity Testing		Final Effluent before Chlorination	Once in the winter and once in the summer the year prior to next permit application	24-hour composite
Reapplication Monitoring					
	Flow	MGD	Final effluent	1/July 1/December	Measurement
	pH (min and max)	Standard Units	Final effluent	1/July 1/December	Measurement
	Temperature	Degrees Celsius	Final effluent	1/July 1/December	Measurement
	BOD	mg/L	Final effluent	1/July 1/December	Grab
	Fecal Coliform	Org/100ml	Final effluent	1/July 1/December	Grab
	Total Ammonia	mg/L N	Final effluent	1/July 1/December	Grab

Category	Parameter	Units	Sample Point	Minimum Sampling Frequency	Sample Type
	Total Residual Chlorine	mg/L	Final effluent	1/July 1/December	Grab
	Dissolved Oxygen	mg/L	Final effluent	1/July 1/December	Grab
	Total Kjeldahl Nitrogen	mg/L N	Final effluent	1/July 1/December	Grab
	Nitrate plus Nitrite N	mg/L N	Final effluent	1/July 1/December	Grab
	Oil and Grease	mg/L	Final effluent	1/July 1/December	Grab
	Phosphorus (Total)	mg/L P	Final effluent	1/July 1/December	Grab
	Ortho Phosphate	mg/L P	Final effluent	1/July 1/December	Grab
	Total Dissolved Solids	mg/L	Final effluent	1/July 1/December	Grab
	Total Hardness	mg/L	Final effluent	1/July 1/December	Grab
	EPA Priority Pollutants - metals, cyanide and phenols. 1M – 15M	µg/L	Final effluent	1/July 1/December	Grab
	EPA Priority Pollutants – Volatile Organic Compounds 1V – 31V	µg/L	Final effluent	1/July 1/December	Grab
	EPA Priority Pollutants – Acid-extractable compounds 1A – 11A	µg/L	Final effluent	1/July 1/December	Grab
	EPA Priority Pollutants – Base-neutral compounds 1B-46B	µg/L	Final effluent	1/July 1/December	Grab
	Whole effluent toxicity testing	Sample final effluent prior to chlorination once in the winter and once in the summer the year prior to next permit application			24-hour Composite

<sup>a</sup> Continuous means uninterrupted except for brief lengths of time for calibration, for power failure, or for unanticipated equipment repair or maintenance. Sampling shall be taken when continuous monitoring is not possible.

B. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136.

C. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements is consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.

D. Laboratory Accreditation

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, chapter 173-50 WAC. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. Conductivity and pH shall be accredited if the laboratory must otherwise be registered or accredited. The Department exempts crops, soils, and hazardous waste data from this requirement pending accreditation of laboratories for analysis of these media.

### **S3. REPORTING AND RECORDING REQUIREMENTS**

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on the effective date of the permit. Monitoring results shall be submitted monthly. Monitoring data obtained during each monitoring period shall be summarized, reported, and submitted on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, by the Department. DMR forms shall be postmarked or received by the Department no later than the 15<sup>th</sup> day of

the month following the completed monitoring period, unless otherwise specified in this permit. Priority pollutant analysis data shall be submitted no later than forty-five (45) days following the monitoring period. Unless otherwise specified, all toxicity test data shall be submitted within sixty (60) days after the sample date. The report(s) shall be sent to the addresses below **respectively**:

Department of Ecology                      and  
Northwest Regional Office  
3190 - 160<sup>th</sup> Avenue SE  
Bellevue, WA 98008-5452

Department of Ecology  
Bellingham Field Office  
1440 10th Street, Suite 102  
Bellingham, WA 98225-7028

All laboratory reports providing data for organic and metal parameters shall include the following information: sampling date, sample location, date of analysis, parameter name, CAS number, analytical method/number, method detection limit (MDL), laboratory practical quantitation limit (PQL), reporting units, and concentration detected. Analytical results from samples sent to a contract laboratory must have information on the chain of custody, the analytical method, QA/QC results, and documentation of accreditation for the parameter.

Discharge Monitoring Report forms must be submitted monthly whether or not the facility was discharging. If there was no discharge during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

B. Records Retention

The Permittee shall retain records of all monitoring information for a minimum of three (3) years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Department.

C. Recording of Results

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling or measurement; (2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) the individual who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Condition S2 of this permit, then the results of such monitoring shall be included in the calculation and reporting of the data submitted in the Permittee's DMR.

E. Twenty-four Hour Notice of Noncompliance Reporting

1. The Permittee must take the following action upon violation of any permit condition:

Immediately take action to stop, contain, and clean up unauthorized discharges or otherwise stop the noncompliance and correct the problem and, if applicable, immediately repeat sampling and analysis. The results of any repeat sampling shall be submitted to Ecology within thirty (30) days of sampling.

2. The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at **(425) 649-7000** and **(360) 715-5208, respectively**, within 24 hours from the time the Permittee becomes aware of the circumstances:
  - a. Any noncompliance that may endanger health or the environment (for example, a fecal coliform measurement in the effluent which is too numerous to count);
  - b. Any unanticipated bypass that exceeds any effluent limitation in the permit (See Part S5.F., “Bypass Procedures”);
  - c. Any upset that exceeds any effluent limitation in the permit (See G.15, “Upset”);
  - d. Any violation of a maximum daily or instantaneous maximum discharge limitation for any of the pollutants in S1.A.; or
  - e. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limitation in the permit.
3. The Permittee must also provide a written submission within five days of the time that the Permittee becomes aware of any event required to be reported under subpart 1, above. The written submission must contain:
  - a. A description of the noncompliance and its cause.
  - b. The period of noncompliance, including exact dates and times.
  - c. The estimated time noncompliance is expected to continue if it has not been corrected.
  - d. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
  - e. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

4. Ecology may waive the written report on a case-by-case basis if the oral report has been received within 24 hours of the noncompliance.
5. Reports must be submitted to the address in S3. (“REPORTING AND RECORDING REQUIREMENTS”).

F. Immediate Noncompliance Notification

Any failure of the disinfection system, and any collection system overflows or plant bypass discharging to a shellfish area shall be reported *immediately* to the Department of Ecology and the Department of Health, Shellfish Program. The Department of Ecology's Northwest Regional Office 24-hour number is **(425) 649-7000**. The Bellingham Field Office number to call is **(360) 715-5208**, and the Department of Health's Shellfish 24-hour number is **(360) 786-4183**.

G. Other Noncompliance Reporting

The Permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for S3.A ("Reporting") are submitted. The reports must contain the information listed in paragraph E above, (“Twenty-four Hour Notice of Noncompliance Reporting”). Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

H. Maintaining a Copy of This Permit

A copy of this permit must be kept at the facility and be made available upon request to Department of Ecology inspectors.

#### **S4. FACILITY LOADING**

A. Design Criteria

Flows or waste loadings of the following design criteria for the permitted treatment facility shall not be exceeded:

Average flow for the maximum month:	0.80 MGD
BOD <sub>5</sub> loading for maximum month:	2088 lbs/day
TSS loading for maximum month:	2642 lbs/day

B. Plans for Maintaining Adequate Capacity

The Permittee shall submit to the Department a plan and a schedule for continuing to maintain capacity when:

1. The actual flow or waste load reaches 85 percent of any one of the design criteria in S4.A for three consecutive months; or
2. The projected increase would reach design capacity within five years,

whichever occurs first. If such a plan is required, it shall contain a plan and schedule for continuing to maintain capacity. The capacity as outlined in this plan must be sufficient to achieve the effluent limitations and other conditions of this permit. This plan shall address any of the following actions or any others necessary to meet the objective of maintaining capacity.

1. Analysis of the present design including the introduction of any process modifications that would establish the ability of the existing facility to achieve the effluent limits and other requirements of this permit at specific levels in excess of the existing design criteria specified in paragraph A, above.
2. Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system.
3. Limitation on future sewer extensions or connections or additional waste loads.
4. Modification or expansion of facilities necessary to accommodate increased flow or waste load.
5. Reduction of industrial or commercial flows or waste loads to allow for increasing sanitary flow or waste load.

Engineering documents associated with the plan must meet the requirements of WAC 173-240-060, "Engineering Report," and be approved by the Department prior to any construction. If the Permittee intends to apply for state or federal funding for the design or construction of a facility project, the plan must also meet the requirements of a "Facility Plan" as described in 40 CFR 35.2030. The plan shall specify any contracts, ordinances, methods for financing, or other arrangements necessary to achieve this objective.

C. Duty to Mitigate

The Permittee is required to take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

D. Notification of New or Altered Sources

The Permittee shall submit written notice to the Department whenever any new discharge or a substantial change in volume or character of an existing discharge into the POTW is proposed which: (1) would interfere with the operation of, or exceed the design capacity of, any portion of the POTW; (2) is not part of an approved general sewer plan or approved plans and specifications; or (3) would be subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act. This notice shall include an evaluation of the POTW's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the POTW, and the anticipated impact on the Permittee's effluent [40 CFR 122.42(b)].

E. Infiltration and Inflow Evaluation

1. The Permittee shall conduct an infiltration and inflow evaluation. A report shall be prepared and received by Ecology on January 31, 2008, and annually thereafter. Refer to the U.S. EPA publication, *I/I Analysis and Project Certification*, available as Publication No. 97-03 at: Publications Office, Department of Ecology, P.O. Box 47600, Olympia, WA 98504-7600. Plant monitoring records may be used to assess measurable infiltration and inflow.
2. A report shall be prepared which summarizes any measurable infiltration and inflow. If infiltration and inflow have increased by more than 15 percent from that found in the first report based on equivalent rainfall, the report shall contain a plan and a schedule for: (1) locating the sources of infiltration and inflow; and (2) correcting the problem.
3. Any infiltration or inflow identified in segments of the collection system which are under or adjacent to surface water (100 yards) shall be further characterized for the existence of exfiltration.
4. The portion of the collection system which connects pump station #1 on Marine Drive, the piping under the mouth of Drayton Harbor, and the piping as it surfaces approximately 100 feet from the shoreline (which is approximately 200 feet from the water pump station) on the western portion of Drayton Harbor, creating the submarine force main under the mouth of Drayton Harbor, shall be leak tested for exfiltration no later than the same schedule as stated above in E.1 of this section.

F. Waste Load Assessment

The Permittee shall conduct an annual assessment of their flow and waste load and submit a report to the Department by January 31, 2008, and annually thereafter. The report shall contain the following: an indication of compliance or noncompliance with the permit effluent limitations; a comparison between the existing and design monthly average dry weather and wet weather flows, peak flows, BOD, and total suspended solids loadings; and the percentage increase in these parameters since the last annual report. The report shall also state the present and design population or population equivalent, projected population

growth rate, and the estimated date upon which the design capacity is projected to be reached, according to the most restrictive of the parameters above. The interval for review and reporting may be modified if the Department determines that a different frequency is sufficient.

## **S5. OPERATION AND MAINTENANCE**

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

### **A. Certified Operator**

An operator certified for at least a Class II plant by the state of Washington shall be in responsible charge of the day-to-day operation of the wastewater treatment plant. An operator certified for at least a Class I plant shall be in charge during all regularly scheduled shifts.

### **B. O & M Program**

The Permittee shall institute an adequate operation and maintenance program for the entire sewage system. Maintenance records shall be maintained on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records shall clearly specify the frequency and type of maintenance recommended by the manufacturer and shall show the frequency and type of maintenance performed. These maintenance records shall be available for inspection at all times.

### **C. Short-term Reduction**

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limitations on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee shall give written notification to the Department, if possible, thirty (30) days prior to such activities, detailing the reasons for, length of time of, and the potential effects of the reduced level of treatment. This notification does not relieve the Permittee of its obligations under this permit.

### **D. Electrical Power Failure**

The Permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations either by means of alternate power sources, standby generator, or retention of inadequately treated wastes.

The Permittee shall maintain Reliability Class I (EPA 430/9-74-001) at the wastewater treatment plant, which requires a backup power source sufficient to operate all vital components and critical lighting and ventilation during peak wastewater flow conditions.

E. Prevent Connection of Inflow

The Permittee shall strictly enforce their sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

F. Bypass Procedures

Bypass, which is the intentional diversion of waste streams from any portion of a treatment facility, is prohibited, and the Department may take enforcement action against a Permittee for bypass unless one of the following circumstances (1, 2, or 3) is applicable.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of this permit, or adversely impact public health as determined by the Department prior to the bypass. The Permittee shall submit prior notice, if possible, at least ten (10) days before the date of the bypass.

2. Bypass which is unavoidable, unanticipated, and results in noncompliance of this permit.

This bypass is permitted only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
- b. There are no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment downtime (but not if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance), or transport of untreated wastes to another treatment facility.
- c. The Department is properly notified of the bypass as required in Condition S3.E of this permit.

3. Bypass which is anticipated and has the potential to result in noncompliance of this permit.

The Permittee shall notify the Department at least thirty (30) days before the planned date of bypass. The notice shall contain: (1) a description of the bypass and its cause; (2) an analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing; (3) a cost-effectiveness analysis of alternatives including comparative resource damage assessment; (4) the minimum and maximum duration of bypass under each alternative; (5) a recommendation as to the preferred alternative for conducting the bypass; (6) the projected date of bypass initiation; (7) a statement of compliance with SEPA; (8) a request for modification of water quality standards as provided for in WAC 173-201A-110, if an exceedence of any water quality standard is anticipated; and (9) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

For probable construction bypasses, the need to bypass is to be identified as early in the planning process as possible. The analysis required above shall be considered during preparation of the engineering report or facilities plan and plans and specifications and shall be included to the extent practical. In cases where the probable need to bypass is determined early, continued analysis is necessary up to and including the construction period in an effort to minimize or eliminate the bypass.

The Department will consider the following prior to issuing an administrative order for this type of bypass:

- a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
- b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
- c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.120.

G. Operations and Maintenance Manual

The approved Operations and Maintenance Manual shall be kept available at the treatment plant and all operators shall follow the instructions and procedures of this manual. In addition to requirements of WAC 173-240-080 (1) through (5) the O&M Manual shall include those conditions and requirements contained in Section G1-4.4 in Ecology's most current version of the "Criteria for Sewage Works Design" (the Orange Book).

The O&M Manual shall be reviewed by the Permittee at least annually beginning January 31, 2008, and the Permittee shall confirm this review by letter to the Department.

**S6. PRETREATMENT**

A. General Requirements

The Permittee shall work with the Department to ensure that all commercial and industrial users of the publicly owned treatment works (POTW) are in compliance with the pretreatment regulations promulgated in 40 CFR Part 403 and any additional regulations that may be promulgated under Section 307(b) (pretreatment) and 308 (reporting) of the Federal Clean Water Act.

B. Wastewater Discharge Permit Required

The Permittee shall not allow significant industrial users (SIUs) to discharge wastewater to the Permittee's sewerage system until such user has received a wastewater discharge permit from the Department in accordance with chapter 90.48 RCW and chapter 173-216 WAC, as amended.

C. Identification and Reporting of Existing, New, and Proposed Industrial Users

1. The Permittee shall take continuous, routine measures to identify all existing, new, and proposed SIUs and potential significant industrial users (PSIUs) discharging or proposing to discharge to the Permittee's sewerage system (see Appendix B of fact sheet for definitions).
2. Within thirty (30) days of becoming aware of an unpermitted existing, new, or proposed industrial user who may be an SIU, the Permittee shall notify such user by registered mail that, if classified as an SIU, they shall be required to apply to the Department and obtain a State Waste Discharge Permit. A copy of this notification letter shall also be sent to the Department within this same thirty (30)-day period.
3. The Permittee shall also notify all PSIUs, as they are identified, that if their classification should change to an SIU, they shall be required to apply to the Department for a State Waste Discharge Permit within thirty (30) days of such change.

D. Industrial User Survey

1. The Permittee shall complete and submit to the Department an Industrial User Survey listing all SIUs and PSIUs discharging to the POTW. The survey shall be received by the Department by January 31, 2011. At a minimum, the list of SIUs and PSIUs shall be developed by means of a telephone book search, a water utility billing records search, and a physical reconnaissance of the service area. Information on PSIUs shall at least include: the business name, telephone number, address, description of the industrial process(es), and the known wastewater volumes and characteristics.

E. Duty to Enforce Discharge Prohibitions

1. In accordance with 40 CFR 403.5(a), the Permittee shall not authorize or knowingly allow the discharge of any pollutants into its POTW which cause pass-through or interference, or which otherwise violates general or specific discharge prohibitions contained in 40 CFR Part 403.5 or WAC-173-216-060.
2. The Permittee shall not authorize or knowingly allow the introduction of any of the following into their treatment works:
  - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21).
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0 standard units, unless the works are specifically designed to accommodate such discharges.
  - c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in sewers or otherwise interfere with the operation of the POTW.
  - d. Any pollutant, including oxygen-demanding pollutants, (BOD, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.
  - e. Petroleum oil, nonbiodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass-through.
  - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
  - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities such that the temperature at the POTW headworks exceeds 40°C (104°F) unless the Department, upon request of the Permittee, approves, in writing, alternate temperature limits.

- h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
    - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).
  3. All of the following are prohibited from discharge to the POTW unless approved in writing by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or the need to augment sewage flows due to septic conditions):
    - a. Noncontact cooling water in significant volumes.
    - b. Stormwater, and other direct inflow sources.
    - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.
  4. The Permittee shall notify the Department if any industrial user violates the prohibitions listed in this section.
  5. Local Limit Development

As sufficient data becomes available, the Permittee shall, in consultation with the Department, reevaluate their local limits in order to prevent pass-through or interference. Upon determination by the Department that any pollutant present causes pass-through or interference, or exceeds established sludge standards, the Permittee shall establish new local limits or revise existing local limits as required by 40 CFR 403.5. In addition, the Department may require revision or establishment of local limits for any pollutant discharged from the POTW that has a reasonable potential to exceed the water quality standards, sediment standards, or established effluent limits, or causes whole effluent toxicity. The determination by the Department shall be in the form of an Administrative Order.

6. The Permittee shall evaluate, at least once every two years, whether each Significant Industrial User needs a plan to control slug discharges. For purposes of this subsection, a slug discharge is any discharge of a nonroutine, episodic nature, including but not limited to an accidental spill or uncustomary batch discharge. The results of such activities shall be available to the Department upon request. If the Permittee decides that a slug control plan is needed, the plan shall contain, at a minimum, the following elements:
          - a. Description of discharge practices, including nonroutine batch discharges.
          - b. Description of stored chemicals.

- c. Procedures for immediately notifying the Permittee of slug discharges, including any discharge that would violate a prohibition under 40 CFR 403.5(b), with procedures for follow-up written notification within five days.
  - d. If necessary, procedures to prevent adverse impact from accidental spills, including inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site run-off, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants (including solvents), and/or measures and equipment necessary for emergency response.
7. Whenever it has been determined, on the basis of information provided to or obtained by the Department, that any waste source contributes pollutants to the Permittee's treatment works in violation of Subsection (b), (c), or (d) of Section 307 of the Act, and the Permittee has not taken adequate corrective action, the Department shall notify the Permittee of this determination. Failure by the Permittee to commence an appropriate enforcement action within thirty (30) days of this notification may result in appropriate enforcement action by the Department against the source and/or the Permittee.

The Department may modify this permit to incorporate additional requirements relating to the establishment and enforcement of local limits for pollutants of concern. Any permit modification is subject to formal due process procedures pursuant to state and federal law and regulation.

## **S7. RESIDUAL SOLIDS**

Residual solids include screenings, grit, scum, primary sludge, waste activated sludge, and other solid waste. The Permittee shall store and handle all residual solids in such a manner so as to prevent their entry into state ground or surface waters. The Permittee shall not discharge leachate from residual solids to state surface or ground waters.

### *RESIDUAL SOLIDS HANDLING*

To prevent water quality problems, the Permittee shall manage all residual solids (grit, screenings, scum, sludge, and solid waste) in accordance with the requirements of: (1) RCW 90.48.080 and water quality standards; (2) applicable sections of 40 CFR Part 503 and chapter 173-308 WAC, "Biosolids Management;" and (3) applicable sections of chapter 173-350 WAC, "Solid Waste Handling Standards."

The final use and disposal of biosolids shall be done in accordance with chapter 173-308 WAC ("Biosolids Management"), 40 CFR Part 503, and under coverage of the state general permit for biosolids management. The disposal of solid waste, other than biosolids, is regulated by the local jurisdictional health department in accordance with state solid waste regulations.

**S8. APPLICATION FOR PERMIT RENEWAL**

The Permittee shall submit an application for renewal of this permit by **May 15, 2012**.

**S9. ACUTE TOXICITY**

A. Testing Requirements

The Permittee shall test final effluent once in the last winter and once in the last summer prior to submission of the application for permit renewal. The two species listed below shall be used on each sample and the results submitted to the Department as a part of the permit renewal application process. The Permittee shall conduct acute toxicity testing on a series of five concentrations of effluent and a control in order to be able to determine appropriate point estimates and an NOEC. The percent survival in 100 percent effluent shall also be reported.

Acute toxicity tests shall be conducted with the following species and protocols:

Winter	Method	Summer	Method
Saltwater Acute Tests		Saltwater Acute Tests	
Daphnid, <i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i>	48-hour static test, method: EPA-821-R-02-012	Daphnid, <i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i>	48-hour static test, method: EPA-821-R-02-012
Pacific herring, <i>Clupea pallasii</i>	96-hour static-renewal test, method: Dinnel/Middaugh Larval Acute (2004)	Fathead minnow, <i>Pimephales promelas</i>	96-hour static-renewal test, method: EPA-821-R-02-012

B. Sampling and Reporting Requirements

1. All reports for effluent characterization or compliance monitoring shall be submitted in accordance with the most recent version of Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria* in regards to format and content. Reports shall contain bench sheets and reference toxicant results for test methods. If the lab provides the toxicity test data on floppy disk for electronic entry into the Department's database, then the Permittee shall send the disk to the Department along with the test report, bench sheets, and reference toxicant results.
2. Testing shall be conducted on 24-hour composite samples of final effluent taken prior to chlorination. Samples taken for toxicity testing shall be cooled to 0 - 6 degrees Celsius while being collected and shall be sent to the lab immediately upon completion. The lab shall begin the toxicity testing as soon as possible but no later than 36 hours after sampling was ended.

3. All samples and test solutions for toxicity testing shall have water quality measurements as specified in Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria* or most recent version thereof.
4. All toxicity tests shall meet quality assurance criteria and test conditions in the most recent versions of the EPA manual listed in subsection A and the Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. If test results are determined to be invalid or anomalous by the Department, testing shall be repeated with freshly collected effluent.
5. Control water and dilution water shall be laboratory water meeting the requirements of the EPA manual listed in subsection A or pristine natural water of sufficient quality for good control performance.
6. Effluent samples for whole effluent toxicity testing shall be collected just prior to the chlorination step in the treatment process.
7. The Permittee may choose to conduct a full dilution series test during compliance monitoring in order to determine dose response. In this case, the series must have a minimum of five effluent concentrations and a control. The series of concentrations must include the ACEC.
8. All whole effluent toxicity tests, effluent screening tests, and rapid screening tests that involve hypothesis testing and do not comply with the acute statistical power standard of 29 percent as defined in WAC 173-205-020 must be repeated on a fresh sample with an increased number of replicates to increase the power.

## **S10. CHRONIC TOXICITY**

### **A. Testing Requirements**

The Permittee shall test final effluent once in the last summer and once in the last winter prior to submission of the application for permit renewal. All of the chronic toxicity tests listed below shall be conducted on each sample. The results of this chronic toxicity testing shall be submitted to the Department as a part of the permit renewal application process.

The Permittee shall conduct chronic toxicity testing on a series of at least five concentrations of effluent and a control in order to be able to determine appropriate point estimates and an NOEC. This series of dilutions shall include the acute critical effluent concentration (ACEC). The ACEC equals 5.26 percent effluent. The Permittee shall compare the ACEC to the control using hypothesis testing at the 0.05 level of significance as described in Appendix H, EPA/600/4-89/001.

Chronic toxicity tests shall be conducted with the following species and the most recent version of the following protocols:

Winter Saltwater Chronic Test	Method	Summer Saltwater Chronic Test	Method
Pacific herring, <i>Clupea pallasii</i>	Dinnel/Middaugh Embryo (2004)	Topsmelt survival and growth, <i>Atherinops affinis</i>	EPA/600/R-95/136
Oyster/Mussel <i>Crassostrea gigas</i> / <i>Mytilus sp.</i> Survival and development	EPA/600/R-95/136	Oyster/ Mussel <i>Crassostrea gigas</i> / <i>Mytilus sp.</i> Survival and development	EPA/600/R-95/136

The Pacific herring test shall run in accordance with the Dinnel/Middaugh embryo test (2004). The Permittee must notify the laboratory one month prior to scheduling the test so that the laboratory can obtain the necessary species.

The Pacific oyster and mussel tests shall be run in accordance with EPA/600/R-95/136 and the bivalve development test conditions in the Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria* or most recent version thereof. The laboratory shall use whichever one of the two species that will give a valid result in each particular test.

**B. Sampling and Reporting Requirements**

1. All reports for effluent characterization or compliance monitoring shall be submitted in accordance with the most recent version of Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria* in regards to format and content. Reports shall contain bench sheets and reference toxicant results for test methods. If the lab provides the toxicity test data on floppy disk for electronic entry into the Department's database, then the Permittee shall send the disk to the Department along with the test report, bench sheets, and reference toxicant results.
2. Testing shall be conducted on 24-hour composite samples of final effluent taken prior to chlorination. Samples taken for toxicity testing shall be cooled to 0 - 6 degrees Celsius while being collected and shall be sent to the lab immediately upon completion. The lab shall begin the toxicity testing as soon as possible but no later than 36 hours after sampling was ended.
3. All samples and test solutions for toxicity testing shall have water quality measurements as specified in Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria* or most recent version thereof.

4. All toxicity tests shall meet quality assurance criteria and test conditions in the most recent versions of the EPA manual listed in subsection A and the Department of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. If test results are determined to be invalid or anomalous by the Department, testing shall be repeated with freshly collected effluent.
5. Control water and dilution water shall be laboratory water meeting the requirements of the EPA manual listed in subsection A or pristine natural water of sufficient quality for good control performance.
6. Effluent samples for whole effluent toxicity testing shall be collected just prior to the chlorination step in the treatment process.
7. The Permittee may choose to conduct a full dilution series test in order to determine dose response. In this case, the series must have a minimum of five effluent concentrations and a control. The series of concentrations must include the ACEC and the CCEC. The ACEC and CCEC may either substitute for the effluent concentration that is closest to it in the dilution series or be an extra effluent concentration.
8. All whole effluent toxicity tests that involve hypothesis testing and do not comply with the chronic statistical power standard of 39% as defined in WAC 173-205-020 must be repeated on a fresh sample with an increased number of replicates to increase the power.

## **S11. OUTFALL EVALUATION**

The Permittee shall inspect the submerged portion of the outfall line and diffuser to document its integrity and continued function. If conditions allow for a photographic verification, it shall be included in the report. The inspection report shall be submitted to the Department by January 31, 2012.

## GENERAL CONDITIONS

### G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed and certified.

- A. All permit applications shall be signed by either a principal executive officer or a ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - 1. The authorization is made in writing by a person described above and submitted to the Department.
  - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- C. Changes to authorization. If an authorization under paragraph B.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph B.2, above, must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

*“I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”*

## **G2. RIGHT OF INSPECTION AND ENTRY**

The Permittee shall allow an authorized representative of the Department, upon the presentation of credentials and such other documents as may be required by law:

- A. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
- B. To have access to and copy - at reasonable times and at reasonable cost - any records required to be kept under the terms and conditions of this permit.
- C. To inspect - at reasonable times - any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
- D. To sample or monitor - at reasonable times - any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

## **G3. PERMIT ACTIONS**

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon the Department's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

- A. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
  - 1. Violation of any permit term or condition.
  - 2. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
  - 3. A material change in quantity or type of waste disposal.
  - 4. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination [40 CFR Part 122.64(3)].
  - 5. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit [40 CFR Part 122.64(4)].
  - 6. Nonpayment of fees assessed pursuant to RCW 90.48.465.
  - 7. Failure or refusal of the Permittee to allow entry as required in RCW 90.48.090.

- B. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:
1. A material change in the condition of the waters of the state.
  2. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
  3. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
  4. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
  5. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR Part 122.62.
  6. The Department has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
  7. Incorporation of an approved local pretreatment program into a municipality's permit.
- C. The following are causes for modification or alternatively revocation and reissuance:
1. Cause exists for termination for reasons listed in A1 through A7 of this section, and the Department determines that modification or revocation and reissuance is appropriate.
  2. The Department has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G8) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

#### **G4. REPORTING PLANNED CHANGES**

The Permittee shall, as soon as possible, but no later than sixty (60) days prior to the proposed changes, give notice to the Department of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in: 1) the permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b); 2) a significant change in the nature or an increase in quantity of pollutants discharged; or 3) a significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation of the terms and conditions of this permit.

## **G5. PLAN REVIEW REQUIRED**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with chapter 173-240 WAC. Engineering reports, plans, and specifications shall be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities shall be constructed and operated in accordance with the approved plans.

## **G6. COMPLIANCE WITH OTHER LAWS AND STATUTES**

Nothing in this permit shall be construed as excusing the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

## **G7. TRANSFER OF THIS PERMIT**

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the Department.

### **A. Transfers by Modification**

Except as provided in paragraph (B) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

### **B. Automatic Transfers**

This permit may be automatically transferred to a new Permittee if:

1. The Permittee notifies the Department at least thirty (30) days in advance of the proposed transfer date.
2. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
3. The Department does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

**G8. REDUCED PRODUCTION FOR COMPLIANCE**

The Permittee, in order to maintain compliance with its permit, shall control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

**G9. REMOVED SUBSTANCES**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

**G10. DUTY TO PROVIDE INFORMATION**

The Permittee shall submit to the Department, within a reasonable time, all information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee shall also submit to the Department upon request, copies of records required to be kept by this permit.

**G11. OTHER REQUIREMENTS OF 40 CFR**

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

**G12. ADDITIONAL MONITORING**

The Department may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

**G13. PAYMENT OF FEES**

The Permittee shall submit payment of fees associated with this permit as assessed by the Department.

**G14. PENALTIES FOR VIOLATING PERMIT CONDITIONS**

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be deemed to be a separate and distinct violation.

#### **G15. UPSET**

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- 1) an upset occurred and that the Permittee can identify the cause(s) of the upset;
- 2) the permitted facility was being properly operated at the time of the upset;
- 3) the Permittee submitted notice of the upset as required in Condition S3.E; and
- 4) the Permittee complied with any remedial measures required under S4.C of this permit.

In any enforcement proceeding, the Permittee seeking to establish the occurrence of an upset has the burden of proof.

#### **G16. PROPERTY RIGHTS**

This permit does not convey any property rights of any sort, or any exclusive privilege.

#### **G17. DUTY TO COMPLY**

The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

#### **G18. TOXIC POLLUTANTS**

The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

**G19. PENALTIES FOR TAMPERING**

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

**G20. REPORTING ANTICIPATED NONCOMPLIANCE**

The Permittee shall give advance notice to the Department by submission of a new application or supplement thereto at least one hundred eighty (180) days prior to commencement of such discharges, of any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility or activity which may result in noncompliance with permit limits or conditions. Any maintenance of facilities, which might necessitate unavoidable interruption of operation and degradation of effluent quality, shall be scheduled during noncritical water quality periods and carried out in a manner approved by the Department.

**G21. REPORTING OTHER INFORMATION**

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Department, it shall promptly submit such facts or information.

**G22. COMPLIANCE SCHEDULES**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than fourteen (14) days following each schedule date.