From: Gent, Philip (ECY)
To: Kaldor, Reed A (Reed_A_Kaldor@rl.gov)
Subject: RATSI
Date: Thursday, December 04, 2014 3:17:23 PM

Reed,

In reviewing 97NM-138, I've read that the less than 5mmBTU/hr boilers would not have any emission limits. I notice in the AOP that 3 limits are imposed on natural gas fired boilers less than 5 mmBTU/hr (of which one is opacity and is generic and needs to stay, but the other two don't seem to have an underlying requirement to be there.)

Additionally, the annual compliance certification has even more emission limits listed than are in the AOP.

I would like to discuss these boilers at the RATSI or just after the RATSI meeting. I'm not sure if we will need a JCI person to be present to discuss.

Philip Gent, PE
Waste Management Section
Nuclear Waste Program
Washington Department of Ecology
Phone: (509) 372-7983
Email: pgen461@ecy.wa.gov
FAX: (509) 372-7971