



Drawing Change Notice

Page 1 of 1

CHANGE DOCUMENT NO.
24590-PTF-MVN-PJV-00007

JOB NO.
24590

TITLE FOR CHANGE NOTICE
Clarification of pin length for lifting ear of O-ring retainer, O-ring groove location, & plate size.



R11013123

DESIGN DOCUMENT NUMBER
24590-PTF-MV-PJV-00002002

REV NO
0

TITLE OF DESIGN DOCUMENT
EQUIPMENT ASSEMBLY, PTF DEMISTER VESSEL, PJV-DMST-00002A/B/C, SHEET 2 OF 2

PART OF DESIGN CHANGE PACKAGE (DCP)? Yes No DCP No.: Rev:

JUSTIFICATION FOR CHANGE
These changes clarify conflicting information shown on the BNI assembly drawing.

TREND CODE-NUMBER ISSUED BY
NA RPP-WTP PDC

Supersedes Change Document Yes No

ECN Needed Yes No

REQUIREMENTS REVIEW

Client Approval Required Yes No Interface Resolution Required * Yes No

Address any "yes" answers in the description

DESCRIPTION OF CHANGE:

1. Show the pin length as 2" minimum in Zone H-3 to agree with Zone E-6.
2. Redraw the double-ended arrow to correctly show the location of the O-ring groove in Zone F-7.
3. Revise plate to 1/4" THK x 2" x 5-1/4" from 1/4" THK x 2" x 3-1/2" in Zone G-4.

ORIGINATOR
Ray Peters *Ray Peters*

CHECKER
Mike Seed *MA Seed*

Reviews

E+NS
GDR
Gerry Hendricks

Approval(s) and Date

JH/zh 1/9/09

Please note that source, special nuclear, and byproduct materials, as defined in the Atomic Energy Act of 1954 (AEA) are regulated at the U. S. Department of Energy (DOE) facilities exclusively by DOE acting pursuant to its AEA authority. DOE asserts that pursuant to AEA, it has sole and exclusive responsibility and authority to regulate source, special nuclear, and byproduct materials at DOE-owned nuclear facilities. Information contained herein on radionuclides is provided for process description purposes only.