

Project Name Skykomish
Project/Task Number 1140204/0360
Calculation Title Air Sparging System Blower Sizing
Prepared by D. Arcieri
Reviewed by M. Havighorst
Completion date 11/4/2007

Objective: To determine minimum blower operating pressure for Area 1 injection wells and future potential injection wells (aka Area 2 Well) based on system head losses and subsurface conditions.

Step 1. Determine Pressure Drop in Straight Runs of Pipe due to friction, h_f

PIPING RUN			PIPE DIA	PIPE DIA	PIPE LENGTH	DESIGN FLOW ^b	DESIGN FLOW ¹	DESIGN VEL. ²	TEMP	Re ³	RELATIVE ROUGHNESS ⁴	FRICTION FACTOR ⁵	HEAD LOSS ⁶	PRESSURE DROP ⁷	PRESSURE DROP ⁸
	FROM	TO	(in)	D (ft)	L (ft)	Q (SCFM)	Q (ACFM)	v (fps)	(deg F)	(dim)	ϵ/D	f (ft)	h_f (ft)	p_{r1} (lbf/ft ²)	p_{r2} (psi)
Area 1	Mech. Bldg.	Vault 1	4	0.33	550	51	66	13	80	24921	1.50E-05	2.45E-02	100	8	0.05
	Vault 1	Area 1 Wells	1	0.08	140 ^a	3	4	12	80	5864	6.00E-05	3.62E-02	133	10	0.07
Total													234	18	0.12
Area 2 ^b	Mech. Bldg.	Vault 2	4	0.33	730	24	31	6	80	11727	1.50E-05	2.97E-02	36	3	0.02
	Vault 2	Area 2 Wells	1	0.08	180 ^c	3	4	12	80	5864	6.00E-05	3.62E-02	172	13	0.09
Total													207	16	0.11

Notes:

- a Pipe length is to the Area 1 sparging well furthest from Vault 1. Length is based on 2008 EDR drawing C-17 takeoff.
- b The locations of the Area 2 vault and sparging wells have not been determined, but would likely be located north of Area 1 and near the South Fork Skykomish River. Area 2 wells and piping would be constructed similarly to those installed in Area 1.
- c Pipe length was estimated based on the predicted location of the future potential Area 2 sparging well furthest from the likely future potential location of Vault 2.

Calculations

1. $Q_{ACFM} = Q_{SCFM} [P_{std} / (P_{act} - P_{sat}\Phi)](T_{act} / T_{std})$ where
 ACFM = Actual Cubic Feet per Minute
 SCFM = Standard Cubic Feet per Minute
 Pstd = Standard absolute air pressure (psia)
 Pact = absolute pressure at the actual level (psia)
 Psat = Saturation pressure at the actual temperature (psi)
 Φ = Actual relative humidity
 Tact = Actual ambient air temperature (R)
 Tstd = Standard temperature (R)

Assumptions:

1. Pact = 13.66 psi at site elevation of 2000 ft above mean sea level
2. Φ = 0.70
3. Tact = 80°F, 540R

2. $v = Q(\pi D^2/4)/(60 \text{ sec/min})$

3. $Re = Dv/\nu$ where
 ν = kinematic viscosity(lbf-sec/ft²)

Assumptions:

Project Name Skykomish
Project/Task Number 1140204/0360
Calculation Title Air Sparging System Blower Sizing
Prepared by D. Arcieri
Reviewed by M. Havighorst
Completion date 11/4/2007

1. $v = 0.000169 \text{ lbf-sec/ft}^2$ at 80°F

4. $\epsilon = 0.000005 \text{ ft}$ where
 ϵ = roughness factor for plastic pipe (Lindeburg, Table 17.2, p. 17-4)

5. $f = \frac{0.25}{\left[\log_{10} \left(\frac{\epsilon}{3.7D} + \frac{5.74}{\text{Re}^{0.9}} \right) \right]^2}$ (Lindeburg, Eq. 17.21)

6. $h_f = fLv^2/(2Dg)$ (Lindeburg Eq. 17.28) where
 g = acceleration of gravity, 32.2 ft/sec²

7. $p_{f1} = h_f \rho g_{\text{air}}$ (Lindeburg, Eq. 17.29(a)) where
 ρg_{air} = specific weight of air at STP, 0.0752 lbf/ft³

8. $p_{f2} = p_f(144 \text{ in}^2/\text{ft}^2)$

Step 2. Determine Pressure Drop in Fittings, h_m

Fitting Type	K	No. of Fittings	HEAD LOSS ⁹ h_m (ft)	PRESSURE DROP ⁷ p_{m1} (lbf/ft ²)	PRESSURE DROP ⁸ p_{m2} (psi)
Area 1					
Mechanical Building					
gate valve (4-inch)	0.19	1	0.47	0.04	0.0002
check valve (4-inch)	2.3	1	5.70	0.43	0.0030
90 elbow (4-inch)	0.9	2	4.46	0.34	0.0023
flow meter	5	1	12.39	0.93	0.0065
Vault A					
gate valve (4-inch)	0.19	1	0.47	0.04	0.0002
tee (4-inch), stem flow	1.8	1	4.46	0.34	0.0023
gate valve (1-inch) 1/2 closed	5.6	1	12.30	0.92	0.0064
tee (1-inch), stem flow	1.8	1	3.95	0.30	0.0021
flow meter	5	1	10.98	0.83	0.0057
Area A Wellheads					
90 elbow (1-inch)	0.9	1	1.98	0.15	0.0010
Total			57.17	4.30	0.03

Project Name Skykomish
Project/Task Number 1140204/0360
Calculation Title Air Sparging System Blower Sizing
Prepared by D. Arcieri
Reviewed by M. Havighorst
Completion date 11/4/2007

Area 2						
Mechanical Building						
gate valve (4-inch)	0.19	1	0.47	0.04	0.0002	
check valve (4-inch)	2.3	1	5.70	0.43	0.0030	
90 elbow (4-inch)	0.9	2	4.46	0.34	0.0023	
flow meter	5	1	12.39	0.93	0.0065	
Vault B						
gate valve (4-inch)	0.19	1	0.10	0.01	0.0001	
tee (4-inch), stem flow	1.8	1	0.99	0.07	0.0005	
gate valve (1-inch) 1/2 closed	5.6	1	12.30	0.92	0.0064	
tee (1-inch), stem flow	1.8	1	3.95	0.30	0.0021	
flow meter	5	1	10.98	0.83	0.0057	
Area B Wellheads						
90 elbow (1-inch)	0.9	1	1.98	0.15	0.0010	
Total			53.32	4.01	0.03	

Calculations

9. $h_m = K v^2 / 2g$ (White, Eq. 6.109)

Step 3. Determine Air Entry Pressure, p_e

Assume air entry pressure due to screen friction is 1 psi

$p_e = 1 \text{ psi}$

Step 4. Determine Total Head Losses Area 1 and 2 Wellheads located furthest from the blower system

$P_{TOTAL} = p_{f2} + p_{m2} + p_e$

Area 1	$P_{TOTAL} = 0.12 \text{ psi} + 0.03 \text{ psi} + 1 \text{ psi} =$	1.15 psi
---------------	---	-----------------

Area 2	$P_{TOTAL} = 0.11 \text{ psi} + 0.03 \text{ psi} + 1 \text{ psi} =$	1.14 psi
---------------	---	-----------------

Project Name Skykomish
Project/Task Number 1140204/0360
Calculation Title Air Sparging System Blower Sizing
Prepared by D. Arcieri
Reviewed by M. Havighorst
Completion date 11/4/2007

Step 5. Determine Overburden Pressure, p_o

Calculations

10. $p_o = p_h + p_s$ where (USACE, Eq. 5-3)

p_h = hydrostatic pressure from the water column = $\rho g_{water}(Z_s - Z_w)\phi$ (USACE, Eq. 5-2)

p_s = soil column pressure = $\rho g_{soil}Z_s(1-\phi)$ (USACE, Eq. 5-1)

ρg_{water} = specific weight of water at STP, 62.4 lbf/ft³

ρg_{soil} = specific weight of soil (lbf/ft³)

Z_s = depth to the top of the well screen (ft)

Z_w = depth to high ground water table (ft)

ϕ = porosity

Assumptions:

1. $\rho g_{soil} = 100$ lbf/ft³

2. $\phi = .5$

From Data:

1. $Z_s = 24$ ft

2. $Z_w = 10$ ft

$p_o = 62.4 \text{ lbf/ft}^3(24\text{ft} - 10\text{ft})(0.5) + 100 \text{ lbf/ft}^3(10\text{ft})(0.5) =$	937	lbf/ft ²
--	-----	---------------------

$p_o = 937 \text{ lbf/ft}^2(144 \text{ in}^2/\text{ft}^2) =$	6.1 psi
--	----------------

Step 6. Determine Range of Maximum Injection Pressure at Well, p_{max}

Calculations

11. $p_{max} = p_o(0.6 \text{ to } 0.8)$ (USACE, Eq. 5-4)

$p_{max} = 6.1(0.6 \text{ to } 0.8) = 3.7 \text{ to } 4.9 \text{ psi}$
--

Step 7. Determine Minimum Blower Pressure, p_{BLOWER} , Based on Total Pressure Loss and Range of Maximum Injection Pressures

Calculations

12. $p_{BLOWER} > p_{max} + P_{TOTAL}$

Area 1	$p_{BLOWER} > 4.9 \text{ psi} + 1.15 \text{ psi} >$	6.05 psi
---------------	---	-----------------

Area 2	$p_{BLOWER} > 4.9 \text{ psi} + 1.14 \text{ psi} >$	6.04 psi
---------------	---	-----------------

Project Name Skykomish
Project/Task Number 1140204/0360
Calculation Title Air Sparging System Blower Sizing
Prepared by D. Arcieri
Reviewed by M. Havighorst
Completion date 11/4/2007

Conclusion: the minimum blower operating pressure is approximately 6.1 psi for each sparging area.

References

1. Lindeburg, Michael R., *Civil Engineering Reference Manual*, 8th Edition, 2001
2. White, F.M., *Fluid Mechanics*, 2nd Edition, 1986
3. United States Army Corps of Engineers (USACE) Engineering Manual (EM) 1110-1-4005 (1997)