

**From:** [John Meier](#)  
**To:** [SW Permit Comments](#)  
**Subject:** Draft Municipal Stormwater Permit Comments  
**Date:** Tuesday, January 10, 2012 2:15:54 PM

---

On page 25 under mandatory list #2 for LID, in the “Roofs” section under line item #5, the section that would allow an impervious roof to drain “below” pervious pavement should be changed to “to and/or below”. Ed Obrien addressed this question at today’s Vancouver workshop and suggested that impervious roofs could drain to or below, but there could be cases where both would apply to a single project and we wouldn’t want a jurisdiction to limit us with interpretations of the language. Therefore, the language “to and/or below” would be effective if either case is acceptable.

**John M. Meier, PE, Principal**

AKS ENGINEERING & FORESTRY

12011 NE 99th St. Suite 1530

Vancouver, WA 98682

360.882.0419x322

[www.aks-eng.com](http://www.aks-eng.com) / [John@aks-eng.com](mailto:John@aks-eng.com)

Offices in: Sherwood, OR and Vancouver, WA

NOTICE: This communication may contain privileged or other confidential information. If you have received it in error, please advise the sender by reply e-mail and immediately delete the message and any attachments without copying or disclosing the contents. AKS Engineering and Forestry shall not be liable for any changes made to the electronic data transferred. Distribution of electronic data to others is prohibited without the express written consent of AKS Engineering and Forestry.