

From: [Ann Hirschi](#)
To: [SW Permit Comments](#)
Subject: Limit soil disturbance
Date: Friday, February 03, 2012 3:33:09 PM

Please note that soil not compacted by construction will absorb stormwater and help mitigate pollutants before they reach the Sound. This will also protect large canopy tree root systems, as the big trees are the best to intercept rainwater before it hits the ground. This should be a part of all LID Best Practices and the permit application requirements. Designation of a "Future Heritage Tree" planting should also be built in, as we plan for tomorrow's canopy cover.

Ann Hirschi, Architect, Certified Arborist
443 25th Ave. E
Seattle WA 98112