

## **APPENDIX 4**

The following category of non-stormwater discharges of flows shall be addressed where such discharges are identified by the municipality or Ecology as sources of pollutants to waters of the state:

**Lawn watering and Landscape irrigation**– Provided that conservation programs to minimize this type of discharge are in place.

**Diverted stream flows** – Provided that all necessary permits or authorizations are received prior to diverting the stream flow.

**Rising ground waters**

**Uncontaminated ground water infiltration (as defined at 40 CFR 35.2005(20)) to separate storm sewers**

**Uncontaminated pumped ground water**

**Water line flushing and discharges from potable water sources** – Provided planned discharges from water lines and potable water sources shall be dechlorinated, pH adjusted if necessary, reoxygenated, and volumetrically and velocity controlled to prevent resuspension of sediments. Water that has been hyperchlorinated shall not be discharged to municipal separate storm sewers, even after de-chlorination.

**Foundation drains**

**Air conditioning condensation**

**Irrigation water**

**Springs**

**Water from crawl space pumps**

**Footing drains**

**Flows from riparian habitats and wetlands**

**Dechlorinated swimming pool discharges** - Provided discharge to a sanitary sewer is not available. Swimming pool discharges shall be dechlorinated, pH adjusted if necessary, reoxygenated, and volumetrically and velocity controlled to prevent resuspension of sediments. Cleaning waste water and filter back wash shall not be discharged to municipal separate storm sewers. Water that has been hyperchlorinated shall not be discharged to municipal separate storm sewers, even after de-chlorination.

**Street wash water** – Provided street wash waters shall be dechlorinated prior to entry into the MS4. At active construction sites, street sweeping must be performed prior to washing the street.