



## King County

### Water and Land Resources Division

Department of Natural Resources and Parks  
King Street Center  
201 South Jackson Street, Suite 600  
Seattle, WA 98104-3855

206-477-4800 Fax 206-296-0192

TTY Relay: 711

## **Echo Lake RSMP Effectiveness Study: Deliverable D1.2: Site Visit (6/2/15)**

### **Personnel Present:**

Carly Greyell (Project Manager), Christopher Barnes (Field Lead), Eric Gilmore (City of Shoreline)

The main purpose of the site visit was to clarify some aspects of the detention tank system (DTS) with the City of Shoreline representative (i.e., pipe materials, baseflow and the correct placement of the outlet flow meter). This information was used for the final QAPP. In addition, the project lead and field team lead checked the status of the Filterra® and bioretention planter box maintenance and verified planned sampling techniques. The photo descriptions include the site locator and the purpose of photo.



**Photo 1: ECHO-DTS-Out (no baseflow observed, pipe materials confirmed)**



**Photo 2: Filterra Inlet, ECHO-FLT#-In** (considered possible barriers to use for sample collection)



**Photo 3: Filterra Outlet, ECHO-FLT#-Out**  
(ensuring effluent sampling location is accessible, teal pipe = clean-out)



**Photo 4: Bioretention Planter Box Inlet, ECHO-BP#-In**

(checking water level in catch basin- still low, but curb cut is clear, so water should enter during a storm event)